

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	Chicago Pneumatic						
	Model Number:	CPVS 40 PM 30kW		Date:	09/30/22			
2	X Air-cooled Water-cooled			Type:	Screw			
				# of Stages:	1			
3*	Full Load Opera	Full Load Operating Pressure		psig ^b				
4	Drive Motor No	minal Rating	40 hp		hp			
5	Drive Motor Nominal Efficiency		95.6	percent				
6	Fan Motor Nomi	Fan Motor Nominal Rating (if applicable)		hp				
7	Fan Motor Nomi	nal Efficiency	51.6	percent				
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	37.9		185	20.46				
8*	28.3		134	21.06				
	22.0		101	21.74				
	15.7		68	23.09				
	8.9		32	2	27.81			
9*	Total Package Input Power at Zero Flow c, d		0.0	kW				
10	Isentropic Efficiency		73.4		%			
11	Specific Power (kW/100 ACFM)	Note: Graph is only a vis Note: Y-Axis Scale, 10 to 35,	100 150 Capacity (ACFM) unal representation of the data in 8 + 5kW/100acfm increments if necess	ection 8	000			

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

Compressed Air & Gas Institut

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- a. Measured at the discharge terminal point of the complessor package in accordance with 15O 1217, Annex E, ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data