

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

| | | MO | DEL DATA - H | FOR COMPRESSEI |) AIR | |
|----|---|--|--|---|--|--------|
| 1 | Manufacturer: | Chicag | go Pneumatic | | | |
| | Model Number: CPVS 50 PM 37kW | | | | Date: 09/30/22 | |
| 2 | X Air-cooled Water-cooled | | | | Type: | Screw |
| | | | | | # of Stages: | 1 |
| 3* | Full Load Operating Pressure | | | 100 | " of Buges. | psig b |
| 4 | Drive Motor Nominal Rating | | | 50 | hp | |
| 5 | Drive Motor Nominal Efficiency | | | 96.0 | percent | |
| 6 | Fan Motor Nominal Rating (if applicable) | | 2.9 | hp | | |
| 7 | Fan Motor Nom | inal Efficier | ісу | 56.0 | percent | |
| 8* | Input Power (kW) | | | Capacity (acfm) ^{a,d} | Capacity (acfm) a,d Specific Power (kW/100 acfm) d | |
| | 43.4 | | | 237 | 18.31 | |
| | 34.5 | | | 190 | | 18.16 |
| | 26.0 | | | 141 | 18.44 | |
| | 18.3 | | | 92 | 19.89 | |
| | 11.1 | | | 44 | | 25.23 |
| 9* | Total Package Input Power at Zero Flow c, d | | | 0.0 | kW | |
| 10 | Isentropic Efficiency | | | 72.6 | | % |
| 11 | Specific Power (KW7100 ACFN) | 35.00 30.00 25.00 20.00 15.00 0 | Note: Graph is only a ote: Y-Axis Scale, 10 to 3. | Loo 150 Capacity (ACFM) visual representation of the data in: 5, +5 \$W/100acfm increments if neces | Section 8 | 50 300 |

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

Compressed Air & Gas Institut

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- a. Measured at the discharge terminal point of the complessor package in accordance with 15O 1217, Annex E, ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

| Volume Flow Rate at specified conditions | | Volume Flow Rate | Specific Energy Consumption | No Load / Zero Flow Power |
|---|-----------------------|------------------|--------------------------------|------------------------------|
| $\underline{m}^3 / \underline{min}$ | ft ³ / min | % | % | % |
| Below 0.5 | Below 17.6 | +/- 7 | +/- 8 | |
| 0.5 to 1.5 | 17.6 to 53 | +/- 6 | +/- 7 | +/- 10% |
| 1.5 to 15 | 53 to 529.7 | +/- 5 | +/- 6 | |
| Above 15 | Above 529.7 | +/- 4 | +/- 5 | |

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data