

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MO	ODEL DATA - FO	OR COMPRESSE	D AIR			
1	Manufacturer: Chie	ago Pneumatic					
	Model Number: CPV		Date:	08/03/20			
2	X Air-cooled Water-cooled			Туре:	Screw		
				# of Stages:	1		
3*	Full Load Operating Pre	Full Load Operating Pressure b		, b psig			
4	Drive Motor Nominal R	Drive Motor Nominal Rating		hp			
5	Drive Motor Nominal E	Drive Motor Nominal Efficiency		percent			
6	Fan Motor Nominal Rat	Fan Motor Nominal Rating (if applicable)		hp			
7	Fan Motor Nominal Effi	ciency	86.5	percent			
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d			
	53.0		239		22.18		
8*	49.0		225		21.78		
	40.0		180		22.22		
	27.0		112		24.11		
	23.0		85		27.06		
9*	Total Package Input Pov	Total Package Input Power at Zero Flow c, d			kW		
10	Isentropic Efficiency	Isentropic Efficiency			%		
11	35.00 30.00 30.00 25.00 (W) 20.00 20.00 15.00 10.00	50 100	150 Eapacity (ACFM)	200 2	50 300		
	Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, +5kW100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity						

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	lume Flow Rate ecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

2/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data