

## COMPRESSOR DATA SHEET

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MO	DEL DAT	A - F(	OR COMPRESSI	ED AIR			
1	Manufacturer:	Chica	igo Pneumat	tic					
	Model Number:	CPVS	S 200 160kW	7		Date:	08	3/30/23	
2	X Air-cooled Water-cooled					Type:	s	crew	
						# of Stages:		1	
3*	Full Load Operating Pressure			125		psig b			
4	Drive Motor Nominal Rating			215		hp			
5	Drive Motor Nominal Efficiency			96.2		percent			
6	Fan Motor Nominal Rating (if applicable)			5.5		hp			
7	Fan Motor Nom	inal Efficie	ency		89.5		percent		
	Input Power (kW)				Capacity (acfm) <sup>a,</sup>		Specific Power (kW/100 acfm) <sup>d</sup>		
	178.0				911		19.54		
8*	149.0				760		19.61		
	130.3				658		19.80		
	112.0				554		20.22		
	74.2			a d	361		20.55		
9*	Total Package Input Power at Zero Flow c, d			0.0		kW			
10	Isentropic Efficiency			76.9		%			
11	Specific Power (kW7100 ACFM)	35.00 30.00 25.00 20.00 15.00	100 200	300 4	, , , , , , , , , , , , , , , , , , ,	) 800 900	1000 1100	- - - -	
			<b>Note: Graph i</b> Note: Y-Axis Scale	s only a vis	Capacity (ACFM) ual representation of the data + 5kW/100acfm increments if no 1 to 25% over maximum capacit	in Section 8 cessary above 35			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- a. Measured at the discharge terminal point of the compressor package in accordance with 15O 1217, Annex E, ACFM is actual cubic feet per minute at inlet conditions.

  b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

  c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data