

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MODEL DA	ATA - FOR CO	MPRESSED	AIR			
1	Manufacturer:	Chicago Pneun	natic					
	Model Number: CPVSd 15 11kW			Date: (08	/16/23	
2	X Air-cooled Water-cooled				Туре:	S	crew	
					# of Stages:		1	
3*	Full Load Operating Pressure			180	psig			
4	Drive Motor Nominal Rating			15	hp			
5	Drive Motor Nominal Efficiency			91.0	percent			
6	Fan Motor Nom	ninal Rating (if applic	able)	0.45 hp			hp	
7	Fan Motor Nom	ninal Efficiency		32.0	percent			
	Input Power (kW)		Capac	city (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d			
	12.0			43	28.30		·	
8*	10.0			34	29.20			
	8.4			27	31.80			
	8.1			25	32.40			
	6.3			17	36.80			
9*	Total Package Input Power at Zero Flow c, d			0.0		kW		
10	Isentropic Effic	sentropic Efficiency					%	
11	Specific Power (kW/100 ACFM)	40.00 35.00 30.00 25.00 20.00 15.00 10.00 Note: Gra	20 Capacity (At applies only a visual represes scale, 10 to 35, + SkW/100a	ntation of the data in S	40 Section 8 Sary shows 35	50	- - - -	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- a. Measured at the discharge terminal point of the compressor package in accordance with 15O 1217, Annex E, ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data