

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		M	ODEI	DAT	A - F	OR C	OMPI	RESSI	ED AI	R				
1 Mar	nufacturer:	Ch	icago Pı	neuma	tic									
Mod	del Number:	CP	VSd 21	15kW						Date	:	08	/16/23	
2	X Air-cooled Water-cooled					Tyj			Туре	: Screw				
									# of	Stages	::		1	
3* Full	ull Load Operating Pressure						150			psig b				
4 Driv	ive Motor Nominal Rating						20			hp				
5 Driv	ve Motor Nominal Efficiency						92.4	ļ		percent				
6 Fan	Motor Nominal Rating (if applicable)						0.25	5		hp				
7 Fan	Motor Nom	Motor Nominal Efficiency					29.5	5		perc				
	Input Power (kW)					Cap	Capacity (acfm) ^{a,d}			Specific Power (kW/100 acfm) ^d				
	19.9						82				24.20		1117	
8*	15.9					66				24.30				
	13.0					53				24.80				
	10.4					40				26.00				
	7.8						28				28.40			
9* Tota	Total Package Input Power at Zero Flow c, d					0.0				kW				
10 Isen	Isentropic Efficiency				51.00				%					
11	Specific Power (kW/100 ACFN)	35.00 30.00 25.00 20.00 15.00			is only a v		sentation o		, 70 in Section		90	100	-	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- a. Measured at the discharge terminal point of the compressor package in accordance with 15O 1217, Annex E, ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	blume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data