

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		МО	DEL DATA -	FOR COMPRE	SSED AIR			
1	Manufacturer:	Chica	go Pneumatic					
	Model Number:	CPVS	6d 29 22kW		Date:	08/16/	23	
2	X Air-cooled Water-cooled				Type:		Screw	
					# of Stages:			
3*	Full Load Operating Pressure			175		psig		
4	Drive Motor Nominal Rating			30		hp		
5	Drive Motor Nominal Efficiency			92.4		percent		
6	Fan Motor Nom	inal Rating	(if applicable)	0.43	0.43 hp			
7	Fan Motor Nom	inal Efficie	ncy	35.0		percent		
	Input Power (kW)		Capacity (acfr	. a.d	Specific Power (kW/100 acfm) ^d			
	27.7		106		26.10			
8*	22.3			86		25.90		
	15.3			58		26.70		
	13.1			49		27.00		
	8.6		28		30.40			
9*	Total Package Input Power at Zero Flow c, d		0.0		kW			
10	Isentropic Efficiency			63.00		%		
11	Spedic Power (kW/100 ACFN)	35.00 30.00 25.00 20.00 15.00 0	Note: Y-Axis Scale, 10 to	Capacity (ACFM) a visual representation of th 35, + 5kW100acfm incremen [6, 0 to 25% over maximum c	ts if necessary above 35	120		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- a. Measured at the discharge terminal point of the compressor package in accordance with 15O 1217, Annex E, ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	blume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m ³ / min	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data