

## COMPRESSOR DATA SHEET

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MO	DEL D	ATA -	FOR (	COMP	RESSE	D AIR				
1	Manufacturer:	Chica	go Pneu	matic								
	Model Number	CPVS	d 34 26	kW				D	ate:	0	08/16/23	
2	X Air-cooled Water-cooled					Туре:			Screw			
								# of Sta	ges:		1	
3*	Full Load Opera	Full Load Operating Pressure				125	5		psig b			
4	Drive Motor Nominal Rating				35			hp				
5	Drive Motor Nominal Efficiency				92.	4		percent				
6	Fan Motor Nominal Rating (if applicable)				1.1:	5		hp				
7	Fan Motor Nom	inal Efficier	Efficiency 32.7					percent				
	Input Powe			Ca	Capacity (acfm) <sup>a,d</sup>			Specific Power (kW/100 acfm) <sup>d</sup>				
	32.1				138			23.40		<u> </u>		
8*	25.5					113			22.70			
	19.4					85			22.70			
	13.3					57			23.30			
	7.5				30			25.50				
9*	Total Package Input Power at Zero Flow c, d				0.0	)		kW				
10	Isentropic Efficiency				64.	4		%				
11	Specific Power (kW/100 ACFN)	35.00 30.00 25.00 20.00 15.00			a visual rep 35, + 5kW/		ements if nec	essary above 3	140	160		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- a. Measured at the discharge terminal point of the compressor package in accordance with 15O 1217, Annex E, ACFM is actual cubic feet per minute at inlet conditions.

  b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

  c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data