

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR Manufacturer: 1 **Chicago Pneumatic** QRSM 20 - 175 psig 8/7/2020 Model Number: Date: 2 Water-cooled Air-cooled Type: Screw # of Stages: acfm^{a,e} Rated Capacity at Full Load Operating Pressure a, e 3* 47.3 Full Load Operating Pressure b psig b 4* 175 Maximum Full Flow Operating Pressure c psig 5 182 Drive Motor Nominal Rating 20 6 hp Drive Motor Nominal Efficiency 91.2 percent Fan Motor Nominal Rating (if applicable) 8 NA hp Fan Motor Nominal Efficiency 9 NA percent Total Package Input Power at Zero Flow kW^{e} 5 10* Total Package Input Power at Rated Capacity and Full Load 13.60 kW^d 11 Operating Pressure^d Package Specific Power at Rated Capacity and Full Load Operating 12* 28.70 kW/100 cfm^e Pressure 13 Isentropic Efficiency 62.27 Percent

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

Member

ROT 030.1

12/19 Rev . This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.