## **COMPRESSOR DATA SHEET**

Rotary Compressor: Variable Displacement

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:		Chicago Pneumatic					
2	Model Number: CPVSd 25				D	ate:	Oct-19	
	x Air-co	ooled	Water-cooled	Ту	pe:	Screw		
	x Oil-in	jected	Oil-free	# of Stag	ges:	1		
3	Rated Operatir	ng Pressur	e	175		psig <sup>b</sup>		
4	Drive Motor N	ominal R	ating	25		hp		
5	Drive Motor N	ominal Ef	fficiency	92.4		percent		
6	Fan Motor No	minal Rati	ing (if applicable)	N/A		hp		
7	Fan Motor No	minal Effi	ciency	N/A		percent		
		Inpu	nt Power (kW)	Capacity (acfm)	a,u -	cific Power /100 acfm) <sup>d</sup>		
			22.7	85.3		26.61		
8*			19.2	71.5		26.85		
			15.5	56.7		27.34		
			12.0	42.1		28.50		
			8.7	26.7		32.58		
9*	Total Package	Total Package Input Power at Zero Flow <sup>c, d</sup>					kW	
10	Specific Power (KW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00	20.0  Note: Graph is only a vis Note: Y-Axis Scale, 10 to 35,		ents if necessary above 35	100.0		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
  - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

-1 -				
Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft3 / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 032 8/14 R1

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.