COMPRESSOR DATA SHEET

Rotary Compressor: Variable Displacement

1	Manufacturer:											
			Chicago P	neumati	c							
	Model Number: CPVSd 10						Date:		:	Jan-19		
2	x Air-cooled Water-cooled						Туре:		:	Screw		
	x Oil-injected Oil-free						# of Stages:		5:	1		
3	Rated Operating	g Pressure	ire 145						psig	0		
4	Drive Motor Nominal Rating						1	0		hp		
5	Drive Motor Nominal Efficiency						91	.0		percent		
6	Fan Motor Nominal Rating (if applicable)						N	Ά		hp		
7	Fan Motor Nominal Efficiency						N	Ά		percent		
	Input Power (kW)					Capacity	(acfm) ^{a,d}		Specific Power (kW/100 acfm) ^d			
	9.8						37	.4		26.20		
8*	8.4						31	.4		26.75		
	7.2						25	5.9		27.80		
	5.9					19	.7		29.95			
	4.6 Min					Min	12	.0		38.33		
9*	Total Package Input Power at Zero Flow ^{c, d}				0.	0		kW				
		40.00										
	Specific Power (kW/100 ACFM)	35.00			$\overline{\ }$							
		30.00										
10		25.00										
10		20.00										
		15.00										
		10.00	5.0	10.0	15.0	20.0	25.0	30.0	35.0	40.0		
	Capacity (ACFM)											

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

		lume Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	%		
	Below 0.5	Below 15	+/- 7	+/- 8		
	0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%	
	1.5 to 15	50 to 500	+/- 5	+/- 6		
ROT 032	Above 15	Above 500	+/- 4	+/- 5		

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data. 8/14 R1

