

0.5 to 1.5

1.5 to 15

Above 15

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Fixed Speed EOD COMPDESSED AID MODEL DATA

	1	MODEL DATA - FOR COMPRES	SED AIK		
1	Manufacturer:	Chicago Pneumatic			
	Model Number:	CPCm 60 - 100 psig	Date:	7/31/2020	
2	X Air-cooled Water-cooled		Type:	Screw	
			# of Stages:	1	
3*	Rated Capacity at Full Load Operating Pressure ^{a, e}		270.2	acfm ^{a,e}	
4*	Full Load Operating Pressure ^b		100	psig	
5	Maximum Full Flow Operating Pressure		107	psig ^c	7
6	Drive Motor Nominal Rat		60	hp	
7	Drive Motor Nominal Eff	iciency	93.6	percent	1
8	Fan Motor Nominal Ratin	ng (if applicable)	1.48	hp	
9	Fan Motor Nominal Effic	iency	84	percent	
10*	Total Package Input Powe	er at Zero Flow ^e	13	kW ^e	
11		er at Rated Capacity and Full Load	52.00	kW ^d	1
12*	Package Specific Power a Pressure ^e	t Rated Capacity and Full Load Operating	19.30	kW/100 cfm ^e	
13	Isentropic Efficiency		69.06	Percent	
	CAGI website for a list of partic : a. Measured at the discl	Performance Verification Program, these items are cipants in the third party verification program: harge terminal point of the compressor package in accord ACFM is actual cubic feet per minute at inlet conditions.	www.cagi.org	idministrator.	
Gal & Gas Institute	 b. The operating pressur for this data sheet. c. Maximum pressure at maximum pressure at d. Total package input p e. Tolerance is specified 	tainable at full flow, usually the unload pressure setting ttainable at full flow, usually the unload pressure setting tainable before capacity control begins. May require ad power at other than reported operating points will vary w d in ISO 1217, Annex C, as shown in table below: power" and "energy" are synonymous for purposes of this	ption (Item 11) were measured for load/no load control or the ditional power. ith control strategy.		
		Volume Flow Rate at specified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Power
nber	$\underline{m^3 / \min}$	<u>ft³ / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	

ROT 030.1

Compr

12/19 Rev .: This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

17.6 to 53

53 to 529.7

Above 529.7

+/- 6

+/- 5

+/- 4

+/- 10%

+/- 7

+/- 6

+/- 5