

## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Potery Compressory Fixed Speed

1	Manufacturer: Chicago Pneumatic		
	Model Number: CPD 100 G - 100 psig / 460V/3ph/60Hz	Date:	9/9/2020
2	X Air-cooled Water-cooled	Type:	Screw
		# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure <sup>a, e</sup>	442.9	acfm <sup>a,e</sup>
4*	Full Load Operating Pressure <sup>b</sup>	100	psig <sup>b</sup>
5	Maximum Full Flow Operating Pressure <sup>c</sup>	107	psig <sup>c</sup>
6	Drive Motor Nominal Rating	100	hp
7	Drive Motor Nominal Efficiency	94.5	percent
8	Fan Motor Nominal Rating (if applicable)	3.5	hp
9	Fan Motor Nominal Efficiency	87.5	percent
10*	Total Package Input Power at Zero Flow <sup>e</sup>	25.6	kW <sup>e</sup>
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	86.30	$kW^d$
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>	19.49	kW/100 cfm <sup>6</sup>
13	Isentropic Efficiency	68.20	Percent



for this data sheet.			
c. Maximum pressure attainable at full	flow, usually the unload pressu	are setting for load/no load con	trol or the

maximum pressure attainable before capacity control begins. May require additional power.

d. Total package input power at other than reported operating points will vary with control strategy.
e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
Member	$\underline{m^3 / \min}$	$\underline{\mathrm{ft}^3} / \mathrm{min}$	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	T/- 10%
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5	
12/10 Decc (TL) 6 1 1		nd Gos Institute for the use of its members participating in		1 4 16 14 4 114	

19 Rev 17 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.