

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Fixed Speed

1	Manufacturer: Chicago Pneumatic		
	Model Number: CPE 120 - 150 psig / 460V/3ph/60Hz	Date:	9/10/2020
2	X Air-cooled Water-cooled	Type:	Screw
		# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure a, e	472.5	acfm ^{a,e}
4*	Full Load Operating Pressure b	150	psig
5	Maximum Full Flow Operating Pressure ^c	157	psig ^c
6	Drive Motor Nominal Rating	125	hp
7	Drive Motor Nominal Efficiency	95	percent
8	Fan Motor Nominal Rating (if applicable)	6.2	hp
9	Fan Motor Nominal Efficiency	89.5	percent
0*	Total Package Input Power at Zero Flow ^e	22.3	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	94.10	kW^d
2*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	19.92	kW/100 cfm ^e
3	Isentropic Efficiency	83.06	Percent

NOTES:



ISO 1217, Annex C; A	ACFM is actual cubic fe	et per minute a	at inlet conditions.	
b. The operating pressure	e at which the Capacity	(Item 3) and E	Electrical Consumptio	n (Item 11) were measured
for this data sheet.				

c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the

maximum pressure attainable before capacity control begins. May require additional power. d. Total package input power at other than reported operating points will vary with control strategy.

e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

a. Measured at the discharge terminal point of the compressor package in accordance with

	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
Member	$\underline{m^3 / \min}$	<u>ft³ / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	T/- 1070
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5	
12/10 Data (TTL) (1 1		ad Cao Instituto for the use of its membrane neutroinstine			

2/19 Rev 17 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.