

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Fired S. **D** - 4 C

1	Manufacturer: Chicago Pneumatic		
	Model Number: CPE 120 - 175 psig / 460V/3ph/60Hz	Date:	9/10/2020
2	X Air-cooled Water-cooled	Type:	Screw
		# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure a, e	419.3	acfm ^{a,e}
4*	Full Load Operating Pressure ^b	175	psig ^b
5	Maximum Full Flow Operating Pressure ^c	182	psig ^c
6	Drive Motor Nominal Rating	125	hp
7	Drive Motor Nominal Efficiency	95	percent
8	Fan Motor Nominal Rating (if applicable)	6.2	hp
9	Fan Motor Nominal Efficiency	89.5	percent
0*	Total Package Input Power at Zero Flow ^e	22.1	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	99.20	kW^d
2*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	23.66	kW/100 cfm ^e
13	Isentropic Efficiency	75.68	Percent

Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

a. Measured at the discharge terminal point of the compressor package in accordance with

NOTES:



	ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
b	. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured
	for this data sheet.

c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the

maximum pressure attainable before capacity control begins. May require additional power. d. Total package input power at other than reported operating points will vary with control strategy.

e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
Member	$\underline{m^3 / \min}$	ft^3 / min	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1076
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5	
12/19 Rev : This form was develo	ped by the Compressed Air	and Gas Institute for the use of its members participating in	the PVP. CAGI has not indepe	ndently verified the reported data	