

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MC	DEL DATA - FO	OR COMPRESSE	D AIR		
1	Manufacturer: Chic	ago Pneumatic				
	Model Number: CPV		Date: 08/07/20		8/07/20	
2	Air-cooled Water-cooled			Type: Screw		Screw
				# of Stages:		1
3*	Full Load Operating Pressure		150	psig b		psig b
4	Drive Motor Nominal Rating		20	hp		
5	Drive Motor Nominal Efficiency		92.4	percent		
6	Fan Motor Nominal Rating (if applicable)		N/A	hp		
7	Fan Motor Nominal Effic	eiency	N/A	percent Specific Power		
8*	Input Power (kW)		Capacity (acfm) ^{a,d}		(kW/100 acfm) ^d	
	19.9		82		24.20	
	15.9		66		24.30	
	13.0		53	24.80		
	10.4		40		26.00	
	7.8		28	28.40		
9*	Total Package Input Power at Zero Flow c, d		0.0	kW		kW
10	Isentropic Efficiency		51.00	%		%
11	35.00 30.00 30.00 25.00 20.00 15.00	Note: Graph is only a visi Note: Y-Axis Scale, 10 to 35, +	40 50 60 apacity (ACFM) ual representation of the data is skW/100acfm increments if nee to 25% over maximum capacity		90 100	-

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

2/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data