

## COMPRESSOR DATA SHEET

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1 Man	ufacturer:		ago Pr			OR CO	WIFK	LOSEI	AIK			
	Model Number: CPVSm 50 37kW								D	ate:		03/25/21
2	X Air-cooled Water-cooled											
- A_	Air-cooled water-cooled								ype:		Screw	
3* Full	I 10 4	· D	b				150		# of Sta	ges:		1 . b
	Load Operating Pressure						150 50		psig			
	Motor Nominal Rating					93.0		hp				
	e Motor Nominal Efficiency  Motor Nominal Rating (if applicable)						1.48		percent hp			
	Motor Nominal Efficiency						84.0		percent			
	Input Power (kW)					Capacity (acfm) <sup>a,d</sup>				Specific Power (kW/100 acfm) <sup>d</sup>		
	42.5					199				21.34		
8*	36.5					170			21.50			
	29.8					137			21.78			
	22.6					101			22.29			
	16.0						69			2	3.22	
9* Tota	al Package Input Power at Zero Flow c, d					0.0		kW				
10 Isen	ropic Efficiency					77.5		%				
11	Specific Power (KN/100 ACPN)	5.00			s only a vis	100 Capacity (A' ual represe	ntation of			200	225	250

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
  b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
  c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	lume Flow Rate ecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data